

Product Information

Date: November 19, 2012

Product: PCS300 (Universal IP Reporting Module)

Subject: Firmware version 2.36 released

Downloads: To download the PCS300 firmware v2.36, [*click here](#)

For upgrade instructions, [*click here](#)

*requires login name and password to download

Improvements: **Input triggers not sending SMS to all phone numbers**

When configuring the PCS300's input triggers to send an SMS message upon an input activation, the PCS300 will now send it's programmed SMS message to all phone numbers selected.

With previous versions of the PCS300, when the Input Activation was only selected, an SMS was only sent to the first phone number. If Input Activation and Deactivation was selected, the PCS300 would then report to all phone numbers.

Message																	
<input checked="" type="checkbox"/> Input Activation	System in alarm. 16 / 80																
<input type="checkbox"/> Input Deactivation	System alarm restored. 22 / 80																
Send to SMS Phone #s	<table border="0"> <tr> <td>#1</td><td>#2</td><td>#3</td><td>#4</td><td>#5</td><td>#6</td><td>#7</td><td>#8</td> </tr> <tr> <td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td> </tr> </table>	#1	#2	#3	#4	#5	#6	#7	#8	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
#1	#2	#3	#4	#5	#6	#7	#8										
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>										

Input triggers on PCS300 reboot

If the PCS300 is now automatically or manually rebooted, the input triggers will not be activated upon boot up and send any unnecessary SMS events.

When the PCS300 was rebooted with any previous version, the input triggers would activate and sends their programmed SMS to all selected phone numbers, causing false system events to be sent via SMS.

Handshake off-hook duration configuration

The 'handshake off-hook duration' value of the PCS300 can now be adjusted if necessary.

With previous versions of the PCS300, when the default value (2000ms) was modified, the PCS300 would not save the modified value and continue to use its default value.

To adjust the value of the handshake off-hook duration, select the 'Other Settings' page from the PCS300 web browser.

CID Dial, Handshake & Kissoff Tones		
Dial tone #1 frequency	<input type="text" value="350"/>	Hz
Dial tone #2 frequency	<input type="text" value="440"/>	Hz
Handshake off-hook duration	<input type="text" value="2000"/>	ms
Handshake tone #1 frequency	<input type="text" value="1400"/>	Hz
Handshake tone #1 duration	<input type="text" value="100"/>	ms
Handshake pause duration	<input type="text" value="100"/>	ms
Handshake tone #2 frequency	<input type="text" value="2300"/>	Hz
Handshake tone #2 duration	<input type="text" value="100"/>	ms
Kissoff tone frequency	<input type="text" value="1400"/>	Hz
Kissoff tone duration	<input type="text" value="750"/>	ms
<input type="button" value="Reset Tones..."/>	Reset the dial tones, the handshake tone sequence and the kissoff tone to the factory default values.	

Contact: If you require additional information or if you have any questions, please do not hesitate to contact our support department.

Email: distributorsupport@paradox.com

Fax: +1.450.491.2313

Phone: +1.450.491.7444 (International)

Paradox Security Systems LTD – Product Information #PCS300-12-11-19